

1981-2010 Station Normals of Temperature, Precipitation, and Heating and Cooling Degree Days

Generated on 03/17/2018

December							January							February							
DATE	MAX	MIN	AVG	HDD	CDD	PRCP	DATE	MAX	MIN	AVG	HDD	CDD	PRCP	DATE	MAX	MIN	AVG	HDD	CDD	PRCP	
01	39.5	24.7	32.1	33	0	43.3% a	01	30.9	16.0	23.4	42	0	43.9% a	01	31.0	14.1	22.5	42	0	39.7% a	
02	39.1	24.4	31.7	33	0	43.4% a	02	30.8	15.9	23.3	42	0	43.8% a	02	31.2	14.1	22.6	42	0	39.6% a	
03	38.6	24.0	31.3	34	0	43.6% a	03	30.6	15.7	23.2	42	0	43.8% a	03	31.3	14.2	22.8	42	0	39.4% a	
04	38.2	23.7	30.9	34	0	43.7% a	04	30.6	15.5	23.1	42	0	43.7% a	04	31.5	14.3	22.9	42	0	39.3% a	
05	37.8	23.3	30.5	34	0	43.7% a	05	30.5	15.4	22.9	42	0	43.6% a	05	31.6	14.4	23.0	42	0	39.2% a	
06	37.4	23.0	30.2	35	0	43.8% a	06	30.4	15.3	22.8	42	0	43.5% a	06	31.8	14.5	23.1	42	0	39.0% a	
07	37.0	22.6	29.8	35	0	43.8% a	07	30.3	15.1	22.7	42	0	43.4% a	07	32.0	14.6	23.3	42	0	38.8% a	
08	36.6	22.3	29.4	36	0	43.8% a	08	30.3	15.0	22.6	42	0	43.3% a	08	32.2	14.7	23.5	42	0	38.7% a	
09	36.2	21.9	29.1	36	0	43.9% a	09	30.2	14.9	22.5	42	0	43.2% a	09	32.4	14.8	23.6	41	0	38.6% a	
10	35.8	21.6	28.7	36	0	44.0% a	10	30.1	14.8	22.5	43	0	43.2% a	10	32.6	15.0	23.8	41	0	38.5% a	
11	35.5	21.3	28.4	37	0	44.0% a	11	30.1	14.7	22.4	43	0	43.1% a	11	32.9	15.1	24.0	41	0	38.4% a	
12	35.1	20.9	28.0	37	0	44.0% a	12	30.1	14.6	22.3	43	0	43.0% a	12	33.1	15.3	24.2	41	0	38.4% a	
13	34.8	20.6	27.7	37	0	44.0% a	13	30.0	14.5	22.2	43	0	42.8% a	13	33.4	15.4	24.4	41	0	38.3% a	
14	34.5	20.3	27.4	38	0	44.0% a	14	30.0	14.4	22.2	43	0	42.6% a	14	33.6	15.6	24.6	40	0	38.2% a	
15	34.2	20.0	27.1	38	0	44.0% a	15	30.0	14.3	22.1	43	0	42.5% a	15	33.9	15.8	24.8	40	0	38.2% a	
16	33.9	19.7	26.8	38	0	44.1% a	16	30.0	14.2	22.1	43	0	42.3% a	16	34.1	16.0	25.1	40	0	38.1% a	
17	33.6	19.4	26.5	38	0	44.2% a	17	30.0	14.1	22.1	43	0	42.1% a	17	34.4	16.2	25.3	40	0	38.1% a	
18	33.4	19.2	26.3	39	0	44.2% a	18	30.0	14.1	22.0	43	0	41.9% a	18	34.7	16.4	25.6	39	0	38.0% a	
19	33.1	18.9	26.0	39	0	44.3% a	19	30.0	14.0	22.0	43	0	41.7% a	19	35.0	16.6	25.8	39	0	37.8% a	
20	32.9	18.6	25.8	39	0	44.3% a	20	30.0	14.0	22.0	43	0	41.5% a	20	35.3	16.9	26.1	39	0	37.7% a	
21	32.7	18.4	25.5	39	0	44.4% a	21	30.1	14.0	22.0	43	0	41.3% a	21	35.6	17.1	26.3	39	0	37.6% a	
22	32.4	18.1	25.3	40	0	44.4% a	22	30.1	13.9	22.0	43	0	41.2% a	22	35.9	17.3	26.6	38	0	37.5% a	
23	32.2	17.9	25.1	40	0	44.4% a	23	30.2	13.9	22.0	43	0	41.0% a	23	36.2	17.6	26.9	38	0	37.4% a	
24	32.0	17.6	24.8	40	0	44.3% a	24	30.2	13.9	22.1	43	0	40.9% a	24	36.6	17.8	27.2	38	0	37.3% a	
25	31.9	17.4	24.6	40	0	44.3% a	25	30.3	13.9	22.1	43	0	40.8% a	25	36.9	18.1	27.5	37	0	37.2% a	
26	31.7	17.2	24.4	41	0	44.2% a	26	30.4	13.9	22.1	43	0	40.6% a	26	37.2	18.4	27.8	37	0	37.1% a	
27	31.5	17.0	24.3	41	0	44.2% a	27	30.4	13.9	22.2	43	0	40.5% a	27	37.6	18.7	28.1	37	0	36.9% a	
28	31.4	16.8	24.1	41	0	44.1% a	28	30.5	13.9	22.2	43	0	40.3% a	28	37.9	19.0	28.4	37	-7777	36.8% a	
29	31.2	16.6	23.9	41	0	44.1% a	29	30.6	13.9	22.3	43	0	40.2% a								
30	31.1	16.4	23.7	41	0	44.0% a	30	30.8	14.0	22.4	43	0	40.0% a								
31	31.0	16.2	23.6	41	0	43.9% a	31	30.9	14.0	22.4	43	0	39.9% a								
MNTH	34.4	20.0	27.2	1172	0	2.34 b	MNTH	30.3	14.5	22.4	1320	0	2.38 b	MNTH	34.0	16.0	25.0	1120	-7777	1.97 b	
							Winter	32.9	16.8	24.8	3612	-7777	6.69 b								
							Annual	57.6	37.3	47.5	6937	549	37.96 b								

a: Probability of precipitation >= 0.01 inches for 29-day windows centered on each day of the year.

b: Long-term averages of seasonal or annual precipitation totals in Inches.

-4444: year-round risk of frost-freeze.

-6666: parameter undefined; insufficient occurrences to compute value.

-7777: a non-zero value that would round to zero.

blank: missing or insufficient data.

1981-2010 Station Normals of Temperature, Precipitation, and Heating and Cooling Degree Days

Generated on 03/17/2018

March							April							May							
DATE	MAX	MIN	AVG	HDD	CDD	PRCP	DATE	MAX	MIN	AVG	HDD	CDD	PRCP	DATE	MAX	MIN	AVG	HDD	CDD	PRCP	
01	38.3	19.3	28.8	36	-7777	36.6% a	01	51.2	30.0	40.6	24	-7777	38.6% a	01	64.3	40.6	52.5	13	-7777	39.2% a	
02	38.6	19.6	29.1	36	-7777	36.6% a	02	51.7	30.4	41.0	24	-7777	38.8% a	02	64.6	41.0	52.8	13	-7777	39.0% a	
03	39.0	19.9	29.4	36	-7777	36.5% a	03	52.2	30.8	41.5	24	-7777	39.0% a	03	64.9	41.3	53.1	12	-7777	38.9% a	
04	39.3	20.2	29.8	35	-7777	36.4% a	04	52.7	31.1	41.9	23	-7777	39.1% a	04	65.3	41.7	53.5	12	-7777	38.9% a	
05	39.7	20.5	30.1	35	-7777	36.4% a	05	53.1	31.5	42.3	23	-7777	39.2% a	05	65.6	42.0	53.8	12	-7777	38.9% a	
06	40.1	20.8	30.4	35	-7777	36.4% a	06	53.6	31.8	42.7	22	-7777	39.3% a	06	65.9	42.4	54.1	11	-7777	38.9% a	
07	40.5	21.1	30.8	34	-7777	36.4% a	07	54.1	32.2	43.1	22	-7777	39.4% a	07	66.2	42.7	54.5	11	-7777	38.9% a	
08	40.8	21.5	31.1	34	-7777	36.4% a	08	54.6	32.6	43.6	22	-7777	39.5% a	08	66.5	43.1	54.8	11	-7777	39.0% a	
09	41.2	21.8	31.5	33	-7777	36.3% a	09	55.0	32.9	44.0	21	-7777	39.7% a	09	66.8	43.4	55.1	10	-7777	39.0% a	
10	41.6	22.1	31.9	33	-7777	36.3% a	10	55.5	33.3	44.4	21	-7777	39.7% a	10	67.0	43.8	55.4	10	1	39.1% a	
11	42.0	22.5	32.2	33	-7777	36.2% a	11	56.0	33.6	44.8	20	-7777	39.8% a	11	67.3	44.2	55.7	10	1	39.1% a	
12	42.4	22.8	32.6	32	-7777	36.1% a	12	56.5	34.0	45.2	20	-7777	39.9% a	12	67.6	44.5	56.1	10	1	39.1% a	
13	42.8	23.2	33.0	32	-7777	36.1% a	13	56.9	34.3	45.6	20	-7777	40.0% a	13	67.9	44.9	56.4	9	1	39.1% a	
14	43.2	23.5	33.4	32	-7777	36.1% a	14	57.4	34.7	46.0	19	-7777	40.0% a	14	68.2	45.2	56.7	9	1	39.2% a	
15	43.6	23.9	33.7	31	-7777	36.1% a	15	57.9	35.1	46.5	19	-7777	40.0% a	15	68.4	45.6	57.0	9	1	39.2% a	
16	44.0	24.2	34.1	31	-7777	36.1% a	16	58.3	35.4	46.9	18	-7777	40.0% a	16	68.7	46.0	57.3	9	1	39.3% a	
17	44.4	24.6	34.5	30	-7777	36.1% a	17	58.8	35.8	47.3	18	-7777	40.0% a	17	69.0	46.3	57.7	8	1	39.3% a	
18	44.9	24.9	34.9	30	-7777	36.3% a	18	59.2	36.1	47.7	18	-7777	39.9% a	18	69.2	46.7	58.0	8	1	39.3% a	
19	45.3	25.3	35.3	30	-7777	36.4% a	19	59.6	36.5	48.0	17	-7777	39.9% a	19	69.5	47.1	58.3	8	1	39.3% a	
20	45.7	25.7	35.7	29	-7777	36.6% a	20	60.1	36.8	48.4	17	-7777	39.9% a	20	69.8	47.4	58.6	7	1	39.2% a	
21	46.2	26.0	36.1	29	-7777	36.7% a	21	60.5	37.2	48.8	16	-7777	39.9% a	21	70.1	47.8	58.9	7	1	39.2% a	
22	46.6	26.4	36.5	29	-7777	36.8% a	22	60.9	37.5	49.2	16	-7777	39.8% a	22	70.4	48.2	59.3	7	1	39.2% a	
23	47.1	26.7	36.9	28	-7777	36.9% a	23	61.3	37.9	49.6	16	-7777	39.7% a	23	70.7	48.5	59.6	7	1	39.1% a	
24	47.5	27.1	37.3	28	-7777	37.1% a	24	61.7	38.2	50.0	15	-7777	39.6% a	24	70.9	48.9	59.9	7	1	39.1% a	
25	48.0	27.5	37.7	27	-7777	37.3% a	25	62.1	38.5	50.3	15	-7777	39.5% a	25	71.2	49.3	60.3	6	2	39.1% a	
26	48.4	27.8	38.1	27	-7777	37.5% a	26	62.5	38.9	50.7	15	-7777	39.4% a	26	71.5	49.6	60.6	6	2	39.0% a	
27	48.9	28.2	38.5	26	-7777	37.7% a	27	62.9	39.2	51.1	14	-7777	39.4% a	27	71.8	50.0	60.9	6	2	39.0% a	
28	49.3	28.6	38.9	26	-7777	37.9% a	28	63.2	39.6	51.4	14	-7777	39.3% a	28	72.1	50.4	61.3	5	2	38.8% a	
29	49.8	28.9	39.4	26	-7777	38.1% a	29	63.6	39.9	51.8	14	-7777	39.3% a	29	72.5	50.7	61.6	5	2	38.7% a	
30	50.3	29.3	39.8	25	-7777	38.3% a	30	63.9	40.3	52.1	13	-7777	39.2% a	30	72.8	51.1	61.9	5	2	38.6% a	
31	50.7	29.7	40.2	25	-7777	38.4% a								31	73.1	51.4	62.3	5	2	38.6% a	
MNTH	44.2	24.3	34.3	953	-7777	2.34 b	MNTH	57.9	35.2	46.5	559	5	3.29 b	MNTH	68.7	46.0	57.4	267	29	4.14 b	
							Spring	56.9	35.2	46.0	1779	35	9.77 b								
							Annual	57.6	37.3	47.5	6937	549	37.96 b								

a: Probability of precipitation >= 0.01 inches for 29-day windows centered on each day of the year.

b: Long-term averages of seasonal or annual precipitation totals in Inches.

-4444: year-round risk of frost-freeze.

-6666: parameter undefined; insufficient occurrences to compute value.

-7777: a non-zero value that would round to zero.

blank: missing or insufficient data.

1981-2010 Station Normals of Temperature, Precipitation, and Heating and Cooling Degree Days

Current Location: Elev: 1080 ft. Lat: 41.9352° N Lon: -84.6411° W

Generated on 03/17/2018

Station: **HILLSDALE, MI US USC00203823**

June							July							August							
DATE	MAX	MIN	AVG	HDD	CDD	PRCP	DATE	MAX	MIN	AVG	HDD	CDD	PRCP	DATE	MAX	MIN	AVG	HDD	CDD	PRCP	
01	73.4	51.8	62.6	5	2	38.5% a	01	82.1	59.1	70.6	1	6	31.8% a	01	81.1	58.8	70.0	1	6	33.0% a	
02	73.8	52.2	63.0	4	2	38.4% a	02	82.2	59.2	70.7	1	6	31.7% a	02	81.0	58.8	69.9	1	6	33.0% a	
03	74.1	52.5	63.3	4	2	38.2% a	03	82.3	59.2	70.8	1	6	31.7% a	03	81.0	58.7	69.8	1	6	33.1% a	
04	74.4	52.8	63.6	4	2	38.0% a	04	82.4	59.3	70.9	1	6	31.6% a	04	80.9	58.7	69.8	1	5	33.1% a	
05	74.8	53.2	64.0	4	3	37.7% a	05	82.5	59.4	70.9	1	6	31.5% a	05	80.8	58.6	69.7	1	5	33.1% a	
06	75.1	53.5	64.3	3	3	37.5% a	06	82.6	59.4	71.0	1	6	31.5% a	06	80.7	58.5	69.6	1	5	33.0% a	
07	75.5	53.8	64.7	3	3	37.2% a	07	82.6	59.4	71.0	-7777	7	31.5% a	07	80.7	58.5	69.6	1	5	33.0% a	
08	75.8	54.2	65.0	3	3	36.9% a	08	82.7	59.5	71.1	-7777	7	31.5% a	08	80.6	58.4	69.5	1	5	33.0% a	
09	76.1	54.5	65.3	3	3	36.7% a	09	82.7	59.5	71.1	-7777	7	31.6% a	09	80.5	58.3	69.4	1	5	32.9% a	
10	76.5	54.8	65.6	2	3	36.4% a	10	82.7	59.5	71.1	-7777	7	31.6% a	10	80.5	58.3	69.4	1	5	32.9% a	
11	76.8	55.1	66.0	2	3	36.1% a	11	82.7	59.5	71.1	-7777	7	31.6% a	11	80.4	58.2	69.3	1	5	32.9% a	
12	77.2	55.4	66.3	2	3	35.9% a	12	82.7	59.5	71.1	-7777	7	31.7% a	12	80.3	58.1	69.2	1	5	32.9% a	
13	77.5	55.7	66.6	2	4	35.6% a	13	82.6	59.5	71.1	-7777	7	31.7% a	13	80.3	58.0	69.1	1	5	32.9% a	
14	77.8	56.0	66.9	2	4	35.3% a	14	82.6	59.5	71.1	-7777	7	31.8% a	14	80.2	57.9	69.1	1	5	32.9% a	
15	78.2	56.2	67.2	2	4	35.0% a	15	82.6	59.5	71.0	-7777	7	31.8% a	15	80.1	57.8	69.0	1	5	32.8% a	
16	78.5	56.5	67.5	2	4	34.7% a	16	82.5	59.5	71.0	-7777	6	31.9% a	16	80.1	57.7	68.9	1	5	32.8% a	
17	78.8	56.7	67.8	1	4	34.5% a	17	82.4	59.5	70.9	-7777	6	31.9% a	17	80.0	57.6	68.8	1	5	32.8% a	
18	79.1	57.0	68.0	1	4	34.3% a	18	82.4	59.4	70.9	-7777	6	32.0% a	18	79.9	57.5	68.7	1	5	32.8% a	
19	79.4	57.2	68.3	1	5	34.1% a	19	82.3	59.4	70.8	-7777	6	32.0% a	19	79.8	57.3	68.6	1	4	32.7% a	
20	79.7	57.4	68.6	1	5	33.8% a	20	82.2	59.4	70.8	-7777	6	32.1% a	20	79.7	57.2	68.4	1	4	32.7% a	
21	80.0	57.6	68.8	1	5	33.6% a	21	82.1	59.3	70.7	-7777	6	32.2% a	21	79.6	57.0	68.3	1	4	32.6% a	
22	80.3	57.8	69.0	1	5	33.4% a	22	82.1	59.3	70.7	-7777	6	32.3% a	22	79.5	56.9	68.2	1	4	32.6% a	
23	80.5	58.0	69.3	1	5	33.1% a	23	82.0	59.2	70.6	1	6	32.4% a	23	79.4	56.7	68.0	1	4	32.5% a	
24	80.8	58.2	69.5	1	5	32.9% a	24	81.9	59.2	70.5	1	6	32.5% a	24	79.3	56.5	67.9	1	4	32.4% a	
25	81.0	58.3	69.7	1	6	32.7% a	25	81.8	59.2	70.5	1	6	32.5% a	25	79.1	56.3	67.7	1	4	32.3% a	
26	81.2	58.5	69.8	1	6	32.5% a	26	81.7	59.1	70.4	1	6	32.6% a	26	79.0	56.1	67.6	1	4	32.3% a	
27	81.4	58.6	70.0	1	6	32.4% a	27	81.6	59.1	70.3	1	6	32.7% a	27	78.8	55.9	67.4	1	4	32.3% a	
28	81.6	58.7	70.2	1	6	32.3% a	28	81.5	59.0	70.3	1	6	32.8% a	28	78.7	55.7	67.2	1	4	32.2% a	
29	81.8	58.9	70.3	1	6	32.1% a	29	81.4	59.0	70.2	1	6	32.9% a	29	78.5	55.4	67.0	2	3	32.2% a	
30	81.9	59.0	70.5	1	6	31.9% a	30	81.3	58.9	70.1	1	6	32.9% a	30	78.3	55.2	66.7	2	3	32.3% a	
							31	81.2	58.9	70.0	1	6	33.0% a	31	78.1	54.9	66.5	2	3	32.3% a	
MNTH	78.1	56.0	67.1	60	121	3.89 b	MNTH	82.2	59.3	70.7	16	194	3.79 b	MNTH	79.9	57.4	68.7	30	143	3.83 b	
							Summer	80.1	57.6	68.8	106	458	11.51 b								
							Annual	57.6	37.3	47.5	6937	549	37.96 b								

a: Probability of precipitation >= 0.01 inches for 29-day windows centered on each day of the year.

b: Long-term averages of seasonal or annual precipitation totals in Inches.

-4444: year-round risk of frost-freeze.

-6666: parameter undefined; insufficient occurrences to compute value.

-7777: a non-zero value that would round to zero.

blank: missing or insufficient data.

1981-2010 Station Normals of Temperature, Precipitation, and Heating and Cooling Degree Days

Current Location: Elev: 1080 ft. Lat: 41.9352° N Lon: -84.6411° W

Generated on 03/17/2018

Station: **HILLSDALE, MI US USC00203823**

September							October							November								
DATE	MAX	MIN	AVG	HDD	CDD	PRCP	DATE	MAX	MIN	AVG	HDD	CDD	PRCP	DATE	MAX	MIN	AVG	HDD	CDD	PRCP		
01	77.9	54.6	66.3	2	3	32.4% a	01	66.4	43.3	54.9	11	1	38.6% a	01	54.1	34.5	44.3	21	-7777	38.9% a		
02	77.6	54.3	66.0	2	3	32.5% a	02	66.0	42.9	54.5	11	1	38.7% a	02	53.7	34.2	44.0	21	-7777	39.0% a		
03	77.4	54.0	65.7	2	3	32.7% a	03	65.6	42.6	54.1	11	-7777	38.7% a	03	53.3	34.0	43.6	21	-7777	39.1% a		
04	77.1	53.7	65.4	2	3	32.8% a	04	65.1	42.2	53.7	12	-7777	38.7% a	04	52.8	33.7	43.3	22	-7777	39.2% a		
05	76.9	53.4	65.1	3	3	33.0% a	05	64.7	41.9	53.3	12	-7777	38.7% a	05	52.4	33.4	42.9	22	-7777	39.4% a		
06	76.6	53.1	64.8	3	3	33.2% a	06	64.3	41.5	52.9	12	-7777	38.7% a	06	51.9	33.2	42.5	22	-7777	39.5% a		
07	76.3	52.8	64.5	3	2	33.5% a	07	63.9	41.2	52.5	13	-7777	38.6% a	07	51.4	32.9	42.2	23	-7777	39.7% a		
08	76.0	52.4	64.2	3	2	33.7% a	08	63.5	40.9	52.2	13	-7777	38.6% a	08	51.0	32.6	41.8	23	-7777	39.8% a		
09	75.6	52.0	63.8	3	2	33.9% a	09	63.1	40.5	51.8	13	-7777	38.6% a	09	50.5	32.3	41.4	24	-7777	40.1% a		
10	75.3	51.7	63.5	4	2	34.0% a	10	62.7	40.2	51.4	14	-7777	38.6% a	10	50.0	32.0	41.0	24	-7777	40.3% a		
11	74.9	51.3	63.1	4	2	34.2% a	11	62.3	39.9	51.1	14	-7777	38.5% a	11	49.5	31.7	40.6	24	-7777	40.4% a		
12	74.6	50.9	62.7	4	2	34.5% a	12	61.9	39.6	50.8	14	-7777	38.4% a	12	49.1	31.4	40.2	25	-7777	40.5% a		
13	74.2	50.5	62.4	4	2	34.7% a	13	61.5	39.3	50.4	15	-7777	38.4% a	13	48.6	31.1	39.8	25	-7777	40.7% a		
14	73.8	50.1	62.0	5	2	35.0% a	14	61.1	39.1	50.1	15	-7777	38.4% a	14	48.1	30.8	39.4	26	0	40.8% a		
15	73.4	49.7	61.6	5	2	35.2% a	15	60.7	38.8	49.7	15	-7777	38.4% a	15	47.5	30.4	39.0	26	0	41.0% a		
16	73.0	49.3	61.2	5	1	35.5% a	16	60.3	38.5	49.4	16	-7777	38.3% a	16	47.0	30.1	38.6	26	0	41.2% a		
17	72.6	48.9	60.8	6	1	35.7% a	17	60.0	38.2	49.1	16	-7777	38.3% a	17	46.5	29.8	38.2	27	0	41.3% a		
18	72.2	48.5	60.3	6	1	36.0% a	18	59.6	38.0	48.8	16	-7777	38.3% a	18	46.0	29.4	37.7	27	0	41.4% a		
19	71.7	48.1	59.9	6	1	36.2% a	19	59.2	37.7	48.5	17	-7777	38.4% a	19	45.5	29.1	37.3	28	0	41.6% a		
20	71.3	47.7	59.5	7	1	36.4% a	20	58.8	37.5	48.1	17	-7777	38.4% a	20	45.0	28.7	36.9	28	0	41.7% a		
21	70.9	47.3	59.1	7	1	36.7% a	21	58.5	37.2	47.8	17	-7777	38.4% a	21	44.5	28.4	36.4	29	0	41.8% a		
22	70.4	46.9	58.7	7	1	37.0% a	22	58.1	37.0	47.5	18	-7777	38.4% a	22	44.0	28.0	36.0	29	0	41.9% a		
23	70.0	46.5	58.2	8	1	37.3% a	23	57.7	36.7	47.2	18	-7777	38.4% a	23	43.5	27.7	35.6	29	0	42.1% a		
24	69.5	46.1	57.8	8	1	37.5% a	24	57.3	36.5	46.9	18	-7777	38.5% a	24	42.9	27.3	35.1	30	0	42.3% a		
25	69.1	45.6	57.4	8	1	37.7% a	25	56.9	36.2	46.6	18	-7777	38.5% a	25	42.4	26.9	34.7	30	0	42.5% a		
26	68.7	45.2	56.9	9	1	37.9% a	26	56.5	36.0	46.3	19	-7777	38.5% a	26	41.9	26.6	34.3	31	0	42.6% a		
27	68.2	44.8	56.5	9	1	38.1% a	27	56.2	35.7	45.9	19	-7777	38.5% a	27	41.4	26.2	33.8	31	0	42.8% a		
28	67.8	44.5	56.1	10	1	38.3% a	28	55.8	35.5	45.6	19	-7777	38.5% a	28	41.0	25.8	33.4	32	0	43.0% a		
29	67.3	44.1	55.7	10	1	38.4% a	29	55.4	35.3	45.3	20	-7777	38.6% a	29	40.5	25.5	33.0	32	0	43.0% a		
30	66.9	43.7	55.3	10	1	38.6% a	30	54.9	35.0	45.0	20	-7777	38.6% a	30	40.0	25.1	32.6	32	0	43.2% a		
							31	54.5	34.8	44.6	20	-7777	38.8% a									
MNTH	72.9	49.4	61.2	167	51	3.77 b	MNTH	60.4	38.7	49.5	484	5	3.13 b	MNTH	47.2	30.1	38.6	791	-7777	3.09 b		
							Autumn	60.1	39.4	49.8	1441	56	9.99 b									
							Annual	57.6	37.3	47.5	6937	549	37.96 b									

a: Probability of precipitation >= 0.01 inches for 29-day windows centered on each day of the year.

b: Long-term averages of seasonal or annual precipitation totals in Inches.

-4444: year-round risk of frost-freeze.

-6666: parameter undefined; insufficient occurrences to compute value.

-7777: a non-zero value that would round to zero.

blank: missing or insufficient data.